

SERVICE LOG IN THE FIRST YEAR.

For one year after the initial start-up. It took place on: _____ / _____ / _____ .

SERVICE STEPS:

AFTER 2 MONTHS:

1. Check the fill level of the suction line _____
2. Check the oil level _____
3. Clean the **FireDos** proportioner and check the equipotential bonding _____
4. Start up the **FireDos** proportioner briefly _____

Date/signature

AFTER 4 MONTHS:

1. Check the fill level of the suction line _____
2. Check the oil level _____
3. Clean the **FireDos** proportioner and check the equipotential bonding _____
4. Start up the **FireDos** proportioner briefly _____

Date/signature

AFTER 6 MONTHS:

1. Check the fill level of the suction line _____
2. Check the oil level _____
3. Clean the **FireDos** proportioner and check the equipotential bonding _____
4. Start up the **FireDos** proportioner briefly _____
5. Clean the filter of the flushing line _____

Date/signature

AFTER 8 MONTHS:

1. Check the fill level of the suction line _____
2. Check the oil level _____
3. Clean the **FireDos** proportioner and check the equipotential bonding _____
4. Start up the **FireDos** proportioner briefly _____

Date/signature

AFTER 10 MONTHS:

1. Check the fill level of the suction line _____
2. Check the oil level _____
3. Clean the **FireDos** proportioner and check the equipotential bonding _____
4. Start up the **FireDos** proportioner briefly _____

Date/signature

AFTER 12 MONTHS:

NOTE

It is recommended to have the annual major service performed by the manufacturer due to its scope and the requirement to determine the proportioning rate.

1. Check the fill level of the suction line _____
2. Check the oil level _____
3. Clean the **FireDos** proportioner and check the equipotential bonding _____
4. Start up the **FireDos** proportioner briefly _____
5. Clean the filter of the flushing line _____
6. Check the leak tightness of the threaded connections of all components _____
7. Check the coupling and grease the shaft _____
8. Check the proportioning rate and ball valves _____
9. Perform an oil change _____
10. Check the pressure in the pulsation damper _____
11. Check the differential-pressure-controlled control valve (special equipment) _____
12. Check the overload protection (special equipment) _____
13. Check the electrical components (special equipment) _____

STAMP

Date/signature